



**LUMINAIRE REQUIREMENTS:**

1. HOUSING: DIE CAST ALUMINUM MAIN BODY USING HEAT-DISSIPATING FINS AND FLOW-THROUGH VENTING.
2. ELECTRICAL: LIGHT ENGINES WITH GREATER THAN L87/60,000 HOURS AND 6KV SURGE PROTECTION.
3. FINISH: FLAT WHITE OR ANTIMICROBIAL WHITE FINISHES AVAILABLE..
4. LAMP: 2 ADJUSTABLE LUMEN PACKAGES WITH UP TO 25,000 LUMENS. REPLACES T150W TO 400W HID.
5. CONTROL: FIXTURE SHALL HAVE INTEGRATED PHOTOCCELL.
6. CERTIFICATIONS: UL LISTED, WET LOCATION, IP66, MINIMUM 1.5 G VIBRATION LOAD PER ANSI136.31.
7. THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

DETAIL BASED ON LITHONIA LIGHTING "ESX" SERIES

# LED AREA LUMINAIRE

REVISED:

LIGHTING PLATE: