



LUMINAIRE REQUIREMENTS:

1. CONSTRUCTION: AIR SUPPLY/RETURN FRAME OPTION. DEPTH OF ONLY 2-3/8".
2. FORM FACTORS: 2x2, 2x4.
3. LUMENS: 2x2 SWITCHABLE BETWEEN 2,900-4,300. 2x4 SWITCHABLE BETWEEN 3,500-5,000.
4. ELECTRICAL: MVOLT. 3500K/4000K/5000K SWITCHABLE; 80 CRI (STANDARD). L80 AT 60,000 HOURS.
5. MOUNTING: FITS INTO STANDARD $\frac{1}{8}$ " AND NARROW $\frac{6}{16}$ " T-GRID CEILING SYSTEMS. DRYWALL GRID ADAPTER OPTION.
6. LISTINGS: DAMP LOCATION. IC RATED.
7. WARRANTY: 5-YEAR LIMITED WARRANTY.

DETAIL BASED ON LITHONIA LIGHTING "BLT ALO/SW" SERIES

TYPE	LUMENS	LAMP TYPE	INPUT WATTS	VOLTAGE	MOUNTING

LED LOW-PROFILE SWITCHABLE FLAT PANEL